

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product : two-pole socket-outlets of the series A, B, C, D, E, F and G
Trade name(s) : NIKO
Type(s)/model(s) : 170-31200+***-66501, 170-31400+***-66501, 170-34200+***-66901/- and 170-34400+***-66901/-

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 7 May 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-113131

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



M. Triulzi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: two-pole socket-outlets of the series A, B, C, D, E, F and G
Trade name(s)	: NIKO
Type(s)/model(s)	: 170-31200+***-66501, 170-31400+***-66501, 170-34200+***-66901/- and 170-34400+***-66901/-
Rated current	: 16 A
Rated voltage	: 250 V~
Method of mounting	: flush-type; screw fixing
Cover	: plural cover plate
Design	: safety socket-outlet
Markings	: -tradename, series indication and electrical ratings on the base -tradename and suffix for the cover on this part

Product data – type 170-31200+*-66501**

Earthing	: without earthing contact
Terminals	: screw terminals

Product data – type 170-31400+*-66501**

Earthing	: without earthing contact
Terminals	: screwless terminals

Product data – type 170-34200+*-66901/-**

Earthing	: with side earthing-contacts
Terminals	: screw terminals

Product data – type 170-34400+*-66901/-**

Earthing	: with side earthing-contacts
Terminals	: screwless terminals

TESTS**Test requirements**

NEN 1020:2019
NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019

Test result

The test results are laid down in DEKRA test file 224284900.

Additional information

The socket-outlets are intended to be used with the cover plates of the Series A, B, C, D, E, F or G

These covers have been constructed as follows:

Serie A

Duoshell (bottom shell: PC/ASA / top shell: Zamac; PC/ASA)

Serie B

Monoshell (PC-ASA)

Serie C

Duoshell (bottom shell: PC/ASA / top shell: inox, metal, forbo, plexi, aluminium, brass, PU+PA, PU)

Serie D

Duoshell (bottom shell: PC/ASA / top shell: bamboo, aluminium)

Serie E

Monoshell (PC-ASA)

Serie F

Housings for surface mounting ((PC-ASA)

Serie G

(PF, optional top shell: PU, resin+sand)

Remark:

This certificate is also based on the SGS CEBEC CB Test Certificate BE-8198

This certificate replaces certificates 2131766.01 and 2181988.01

Conclusion

The examination proved that all requirements were met.

Factory location

Niko N.V.

Industriepark West 40

9100 Sint-Niklaas, Belgium