

# CERTIFICATE

Issued to:  
Applicant:  
**Niko N.V.**  
Industriepark West 40  
9100 Sint-Niklaas, Belgium

Licensee:  
**Niko N.V.**  
Industriepark West 40  
9100 Sint-Niklaas, Belgium

Product : Two-pole fixed socket-outlet with earthing-contact  
Trade name(s) : NIKO  
Type(s)/model(s) : \*\*\*\_67815, \*\*\*\_67825, \*\*\*\_67835, \*\*\*\_67845 and \*\*\*\_67865

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019, NEN-IEC 60884-1:2019/A2:2019 and NEN 1020:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 20 November 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-116374

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



H.R.M. Barends  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Two-pole fixed socket-outlet with earthing-contact
Trade name(s)	: NIKO
Type(s)/model(s)	: ***_67815, ***_67825, ***_67835, ***_67845 and ***_67865
Rated current	: 16 A
Rated voltage	: 250 V~
Standard sheet	: III of CEE7
Design	: two-fold
Method of mounting	: flush-type
Cover	: singular cover plate of thermoplastic material
Terminals	: screwless terminals
Earthing	: with side earthing-contacts
Markings	: -tradename, series-indication and electrical ratings on the socket-outlet

**TESTS****Test requirements**

NEN-IEC 60884-1:2019  
NEN-IEC 60884-1:2019/A1:2019  
NEN-IEC 60884-1:2019/A2:2019  
NEN 1020:2019

**Test result**

The test results are laid down in DEKRA test file 217422600, 225032500.

**Additional information**

This certificate replaces certificate No. 2174226.01 which we hereby declare invalid.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

Niko N.V.  
Industriepark West 40  
9100 Sint-Niklaas, Belgium