

# LICENCE

**No. 17583 - Issue No 2**

Issued to:  
Applicant:  
**NIKO N.V.**  
**Industriepark-West 40**  
**9100 SINT-NIKLAAS**  
**Belgium**



Licensee:  
**NIKO N.V.**  
**Industriepark-West 40**  
**9100 SINT-NIKLAAS**  
**Belgium**



Product : transformers, safety isolating-, general purpose  
Trade name(s) : NIKO  
Type(s)/model(s) : 320-00001, 320-00002

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 14

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The ENEC/CEBEC certification mark may be applied to the product as specified in this licence for the duration of the ENEC/CEBEC certification agreement and under the conditions of the ENEC/CEBEC certification agreement.

This licence is issued on : 20/01/2015



ir. C. Lana,  
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed  
This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



**SGS Belgium NV-Division SGS CEBEC**  
**Business Riverside Park**  
**Bld Internationaaleaan 55 Build. D**  
**B-1070 Brussels**  
**Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36**

This certificate is issued by the company under its General Conditions for Certification Services accessible at [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SPECIFICATION OF THE CERTIFIED PRODUCT**

**Product data**

Product : transformers, safety isolating-, general purpose  
 Trade name(s) : NIKO  
 Type(s)/Model(s) : 320-00001, 320-00002  
 rated voltage (Un) : 230 - 240 V  
 description : Independent short circuit proof transformer  
 rated output voltage (Un out) : 11.5 V  
 nature of supply : AC  
 rated frequency : 50 Hz  
 rated output current (In out) : 4 A  
 rated output(s) : 35 VA  
 class : II  
 degree of protection : IP 20

**Product data - type 320-00001**

connection : lead wires

**Product data - type 320-00002**

connection : screw terminals

**TESTS**

**Test requirements**

EN 61558-1:2005 + A1:2009  
EN 61558-2-6:2009

**Remarks**

This certificate is based on test report ref.587658.02\_SMT11-009


**Conclusion**

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 20/01/2015

Department Manager, Product Certification :

Certification Manager :



2015-01-20

**FACTORY LOCATION(S)**

Ningbo Wanji Electronics Science & Technology Co. Ltd.  
Industrial Zone, Andong Town  
Cixi City  
315327 NINGBO  
China