
# R.F.G.

# B.E.G. LUXOMAT® TS-ACC-DS2

Installation and Operating Instruction for B.E.G. PC-Software







# 1. Directory


1. Dire	ctory	. 2
2. 2.1. 2.2. 2.3. 2.4.	Introduction	. 3 . 3 . 4
<b>3.</b> 3.1. 3.2. 3.3.	Program start and languages Start icon Define type of time switch Adjustment of the language	. 8 . 8
4.1.2. 4.1.3. 4.1.4.	Overview, menu and symbols Program overview Table Chart Switch the mode of view Refresh chart Choose the period you are interested in! Menu bar - overview Toolbar	. 9 . 9 . 9 10 10
5.3. 5.3.1.	Programming of a new switching time	12 13 14 15
<b>6.</b> 6.1. 6.2.	<b>Data key functions</b> Read data key Write data key	16
<b>7.</b> 7.1. 7.2. 7.3. 7.3.1. 7.4.	Further information	17 17 18 18



# 2. Introduction

# 2.1. Product description

The PC-Software **TS-ACC-DS2** is a tool for a quick and easy creation of a switching program. Via USB-adapter **TS-ACC-DS2** and data key **TS-ACC-DS1** the switching program can be transferred between the time switch and the PC.



# 2.2. Pictograms

Pictograms	Defintion
INFO	Information The pictogram offers helpful information.
	Title of a handling sequence The pictogram shows the handling sequence.
	Elements of a handling sequence The pictogram prompts the user to carry out an action!



### 2.3. Software installation

Please carry out following instructions for installing the programming software **TS-ACC-DS2** successfully under Windows (2000, XP, VISTA):



Software installation

Insert CD TS-ACC-DS2 into CD/DVD-drive.

Installation starts automatically, please carry-out advises of the routine.

TS-ACC-DS2 will add an icon on the desktop and will be added within the start menu

(Start menu: Start ▶ programs ▶ LU-TS-ACC-DS2 ▶ ...)

If the installation does NOT start automatically please carry out following sequence:

Open CD-directory and execute file Setup\_LU\_TS\_ACC\_DS2.exe

Follow the on screen instructions



### 2.4. Hardware installation

Please carry-out following instructions for installing the USB adapter **TS-ACC-DS2** successfully under Windows (2000, XP, VISTA):



STEP 1 - Connect USB-cable

Connect B-USB-connector of the cable (included in delivery) to adapter **TS-ACC-DS2**.

Connect A-USB-connector of the cable with your computer.



STEP 2 – Driver installation

After Step 1 the hardware installing tool of windows starts automatically:

Choose: "No, ...".

Confirm with "Next ▶".



Choose: "Install from a list or specific location".

Confirm with "Next ▶".



Confirm:

"Search for the best driver in these location".

© Confirm: "Include this location in the search".

Click: "Browse".

Enter the path to sub-folder "Driver" on CD TS-ACC-DS2.

Confirm with "Next ▶".









- Choose: "Install from a list or specific location".
- Confirm with "Next ▶".



Confirm

"Search for the best driver in these location".

Confirm: "Include this location in the search".

Click: "Browse".

Enter the path to sub-folder "Driver" on CD TS-ACC-DS2.

© Confirm with "Next ▶".

INFO

Windows copies driver.



Complete the installation by clicking "Finish".

INFO

The hardware is now ready to use.



# 3. Program start and languages

### 3.1. Start icon



Start the PC-software LU-TS-ACC-DS2 by a double click of the **B.E.G.** start-symbol.

<u>OR</u>

Execute LU-TS-ACC-DS2 within "windows" start menu Start ➤ Programs ➤ LU-TS-ACC-DS2 ➤ LU-TS-ACC-DS2.

# 3.2. Define type of time switch



The program starts with a welcome window.

- Choose the desired product type.
- © Confirm with "Next ▶".

# 3.3. Adjustment of the language





### STEP 1

To change the languages please proceed as follows:

- Click menu "Adjustment".
- Click menu "Language".





- Choose language.
- Confirm with "OK"



Restart the program.



The new language configuration will be activated only after a restart of the software.



# 4. Overview, menu and symbols

# 4.1. Program overview

You have the choice between two different views of your switching program: **Table** and **chart**.


### 4.1.1. Table

Default view is "table" and the switching steps are listed as lines.



### 4.1.2. Chart

You always have the possibility to switch between table and chart. If you switch to chart, three different charts with time dependent switching status of all channels will appear.





**PLEASE NOTE:** Special program (**SP 1 ... 10**) and extra switching times (**EXTRA**) will **NOT** shown in the chart!

# 4.1.3. Switch the mode of view





Show chart / Refresh chart



Click "Refresh chart" symbol.





Show table

Click "Show table" symbol.



# 4.1.4. Refresh chart

If you are working with the chart, new switching times will only be shown if you refresh the chart by click "Refresh chart" symbol.




Click "Refresh chart" symbol.

New switching steps will only be shown after refreshing the chart.

The more memory locations you use, the longer it takes to refresh/show the chart. This can take up to 1 minute!

# 4.1.5. Choose the period you are interested in!



1. Yearly / 2. Weekly / 3. Daily / 4. Hourly



### 4.2. Menu bar - overview

File	Edit	Data key	Adjustments	View	Help
New project	New switching time	Reading data key	Language	Status bar	Manual
Open	Duplicate	Programming data key	Project description	Toolbar	About
Open last project	Delete		Channel description	Show chart	
Close project		-	Astro settings*	Show table	
Save project			Cycle settings*		
Save project as			Location project files		
Export file as CSV	7				

# 4.3. Toolbar

The toolbar of LU-TS-ACC-DS2 is as follows:



Icon	Name: Description					
0	New switching time: Enter new switching time					
80	Duplicate: Enter new standard switching time on the basis on an existing one					
1	Open project: Open existing project file					
	Save project					
×	<b>Delete:</b> Delete marked switching Step					
ESV	CSV export: Export switching program as coma separated file					
C.	Reading data key: Read memory of the data key into the PC					
£=	Programming data key: Write switching program from the PC-program to the data key					
Dr Dr	1. Cycle settings (black): Open cycle settings					
J U or	2. Cycle settings (grey): Cycle function is not available for this time switch					
wag.	Refresh chart: Refreshes or shows charts of the time dependent switching functions					
<b>III</b>	Show table: Show switching program as table					



# 5. Programming of a new switching time

# 5.1. Programming of a standard switching time





Click "New switching time".

<u>OR</u>

Double click an empty line within the table.



Window "new switching time" opens!





Choose the channel/channels for which you would like to enter a switching time.

© Confirm with "OK ▶".





Choose program type **STANDARD**.

© Confirm with "OK ▶".





Choose the desired switching function.

Standard weekly time switch: ON-/OFF or PULSE
Astro timers: ON-/OFF or ASTRO

Weekly time switch with cycle function: ON-/OFF, PULSE,

CICLE

(F)

Yearly time switches: **ON-/OFF, PULSE, CYCLE\***\*Will only be offered after activation of Cycle(s).

Trin only be energe and demanding of e

Confirm with "OK ▶".



FURTHER STEPS

Further programming steps depend on the choice of the switching function (Step 4). Follow further advices within window "new switching time".



# 5.2. SP special program (yearly time switch)

The yearly function is fulfilled by the use of so called special (weekly) programs (SP) which are later activated (called up) by date as often as required. You can define up to 10 different special programs with arbitrary switching steps (of course only within the total number of 300 memory locations).

The SP will only be applied if activated by date (SP Activation

The SP will only be applied if activated by date (SP Activation by date see point 5.2.1).





Click "New switching time".

OR

Double click an empty line within the table.



Window "new switching time" opens!






Choose the channel/channels for which you would like to enter a switching time.

© Confirm with "OK ▶".



# STEP 3

INFO If you define a new switching time "SP = special program", you have to choose a SP-Number FIRST (SP 1 – SP 10).



Choose program type SP 1 – SP 10.

© Confirm with "OK ▶".



# STEP 4

Choose the desired switching function.



© Confirm with "OK ▶".







# **FURTHER STEPS**

Further programming steps depend on the choice of the switching function (Step 4). Follow further advices within window "new switching time".

A SP will only be applied after Activation (call up by date) ▶ see point 5.2.1.

# 5.2.1. Activation of a special program (yearly time switch)

Special programs will only be applied if activated (called up) by date. SP can be called up as often as required (limited only by the max. quantity of memory locations). The activation requires start date and end date of the date period.





# STEP 1

(P) Click "New switching time".

<u>OR</u>

(F) Double click an empty line within the table.

Window "new switching time" opens!





### STEP 2

(F Choose the channel(s) for which you would like to activate a special program.

Confirm with "OK ▶".





(F) Choose the SP (SP 1 - SP 10) to be activated.

Confirm with "OK ▶"





Choose "Activate SP" as switching function.

(F) Confirm with "OK ▶"




# Programming of a new switching time





- Enter "start date" and "end date" of your special program.
- © Confirm with "OK ▶".





- A "Special function" can be activated optionally (standard is NO special function).
- © Confirm with "OK ▶".

# 5.3. Add-Ons



The following functions are **NOT** included in all types of time switches!

# 5.3.1. Extra switching time

Extra switching time is one single additional switching time that can be programmed by date. This switching time is executed additionally to the active switching program. If you like to program an extra switching time choose "EXTRA" as program type.

### 5.3.2. Permanent program

The program type permanent (permanent by date, holiday program) is a permanent On or Off status for the desired channel and activated by date (start date till end date). A permanent switching program can be called up as often as required (limited only by the max. quantity of memory locations).

If you like to program an extra switching time choose "PERMANENT" as program type.



# 6. Data key functions

INFO

For a successful data transfer the time switch and the type of time switch of the PC project must be identical!

# 6.1. Read data key



STEP 1

Click symbol "read data key".

INFO

Window "LU-TS-ACC-DS2" opens if project is empty!





Click "read data key".

Data is now read from the data key!





© Confirm with "OK ▶".

INFO

All switching times will be shown on the screen of the PC!

### 6.2. Write data key





Click symbol "read data key".

INFO

Window "LU-TS-ACC-DS2" opens!



# STEP 2

Click "write to data key".

INFO

Data is now written to the data key!

Existing data on the data key will be lost!





Confirm with "OK ▶".

All switching times which are marked for transfer are written to the data key and can be copied to the time switch of the same type.

INFO If y

If you do so, the existing switching program of the time switch will be overwritten!



# 7. Further information

# 7.1. Refreshing the chart

While working with the chart view and if you enter a new switching time you have to refresh the chart before you see the switching time in the diagram.




# 7.2. Duplication

Standard switching times "ON/OFF", "PULSE" or "CYCLE" can quickly and easily be duplicated.



STEP 1

Click symbol "duplicate".





STEP 2

This offset value is added to the switching time chosen for copy.

Confirm with "OK ▶".



# 7.3. Cycle function

The cycle is not offered as switching function until you have defined a cycle. You have to define the cycle you would like to use first as follows:

# 7.3.1. Cycle activation and definition







Up to four different cycles can be activated and defined within this window.

Activate the desired **cycle** number (click).





The max. **pulse** and **pause** length is 9:59:59 (h:mm:ss) each.

- Define Pulse and Pause lenght.
- © Confirm with "OK ▶".

# 7.3.2. Saving / Location project files



# Location of project files

- Click "Adjustments".
- Click submenu "Location project files".
- Define a project directory.



# Article / Part-Nr. / Accessory

Digital time switches with data key function (accessory)		
<b>LUXOMAT®</b> weekly time switch TS-DW2	92658	
<b>LUXOMAT®</b> weekly time switch TS-DW3	92659	
<b>LUXOMAT®</b> weekly time switch with Astro function TS-ASTRO2	92671	
<b>LUXOMAT®</b> weekly time switch with Astro function TS-ASTRO3	92673	
LUXOMAT® Yearly time switch TS-DY1	92674	
<b>LUXOMAT®</b> Yearly time switch TS-DY2	92675	
Data key LUXOMAT® TS-ACC-DS1		
PC-Programming package with USB connection <b>LUXOMAT®</b> TS-ACC-DS2	92685	